

Consequence Model Modifications Since March, 2006 Release of 8.0

API RBI User Group Meeting
Houston Marriott Greenspoint



Philip A. Henry
October 5, 2006

PROPRIETARY INFORMATION
For Authorized Company Use Only



Recent changes made to Consequence Modeler, version 8.0

- Corrected the isentropic flash, would crash for very low entropies
- Corrected flash routine to handle negative pressure
- Corrected outage day equation for financial consequences

$$Outage_{affa} = 10^{(1.242 + 0.59 \times \log_{10} FC_{affa})}$$

- Corrected mitigation time in new consequence modeler (seconds versus minutes)
- Corrected Metric defaults for the thermal radiation limits, they were off by a factor of 1000 (W/m² to Btu/hr-ft²). As a result, the consequence areas for the NEW consequence model were extremely high when using metric units

Recent changes made to Consequence Modeler, version 8.0

- Corrected flash calculation for a fluid stored as a liquid that flashes to a super-critical fluid, e.g. EO
- Corrected data initializations, especially for consequence modeler - many of the variables were not being wiped clean during the batch calculations and it was compromising the results of other runs.
- Corrected flash routine, only the first fluid component in the composition was being used in the flash calculation; effected inventories
- Corrected cloud source dimensions for instantaneous releases of vapor, source area was way too large (vapor consequences too high)

Recent changes made to Consequence Modeler, version 8.0

- Corrected pool fire dimensions – Radiation distance was being calculated correctly, but was adding total safe distance to outer edge of pool (liquid consequence too high)
- Corrected inventory mass value being sent from APIRBI to PRV module, was sending zero since it was using the wrong variable name
- Reverted back to using the User input value or the default values for RP581 for LV % (Major change from 8.00.005 to 8.1)
 - Eliminated the User estimated vapor and liquid volumes. The user still has the ability to input an estimated component mass and an estimated LV percent.
- Set pressure for calculations to 15 psig if the design and operating pressures are set to zero

Recent changes made to Consequence Modeler, version 8.0

- Cleaned up consequence inventory calculations in consequence model by assuring that a vapor density and liquid density will always be calculated
- Corrected conversion factor for population density
- Modified shutdown days keyword to make it a float instead of an integer, also changed default value for 3 to 0 days– PRV Module
- Corrected the metric unit conversions for back pressure, ambient pressure, overpressure, set pressure, upstream source pressure and deadhead pressure.



20600 Chagrin Blvd. • Suite 1200
Shaker Heights, OH 44122 USA
Phone: 216-283-9519 • Fax: 216-283-6022
www.equityeng.com